

Declaration of Performance

No. HB-DOP-0011

1. Unique identification code of the product type: Firescreen® Smoke

2. Type number: D120

3. Intended use:

Active smoke barriers (designated ASB) comprising flexible curtains deployed from overhead barrels either as; a single curtain maximum 11.00m wide x 6.00m high, or; multiple curtains, installed next to each other, each max. 11.00m wide x 6.00m high of unlimited overall width with free overlap at least 420mm. Barrels are adjacent or one above the other. All configurations are classified D120.

4. Name and address of manufacturer: Hoefnagels Branddeuren BV
Zevenheuvelenweg 50
5048 AN Tilburg
Nederland

5. Name and address of reprehensive: not relevant

6. System of assessment and verification of constancy of performance: EN 12101-1: 2006

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:


Notified product certification body IFC Certification Ltd, No. 1720, performed the determination of the product type on the basis of type testing (including sampling), initial inspection of the manufacturing plant and of the factory production control and continuous surveillance, assessment and evaluation of factory production control and issued the certificate of constancy of performance of the product.

8. Declared performance:

Essential characteristics	Performance	Harmonized techn. Specification
Operational reliability	Pass	EN 12101-1: 2006
Response delay	Pass	
Deployment safety	Pass	
Fire Resistance – Smoke leakage	Pass	
Fire Resistance – Mechanical Stability	D120	
Fire Resistance – Integrity	D120	

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



G.J.B. Hoefnagels, director

Tilburg, 13-8-2019